








- NOTES:
1. ALL INTERCONNECTING PIPE AND FITTINGS SHALL BE INSTALLED BY THE CONTRACTOR.
 2. ALL PIPING SHALL BE HARD-DRAWN SEAMLESS TYPE "L" OR TYPE "K" COPPER TUBING CONFORMING TO ASTM DESIGNATION B-819.
 3. ALL PIPING SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITION OF NFPA 99 OR ISO Z7396.1. CONTRACTOR WILL BE RESPONSIBLE FOR FIELD VERIFICATION AND COORDINATING ACTUAL LOCATION WITH ALL OTHER TRADES.
 4. EQUIPMENT, INSTALLATION, AND TESTING OF THE MEDICAL GAS SYSTEM SHALL COMPLY WITH THE LATEST EDITION OF NFPA 99 OR ISO Z7396.1, AND ALL STATE AND LOCAL CODES OR ORDINANACES.
 5. SINGLE SERVICE HOSE REEL WEIGHT: 32 LBS.
 6. DOUBLE SERVICE HOSE REEL WEIGHT: 42 LBS.



Revised:	Date:	Drawn: SMB	Date: 12/17/2020
	This drawing and the information contained herein remain the property of BeaconMedaes and may not be used for other than the purpose for which it is loaned without the expressed written permission from BeaconMedaes Engineering.		Scale: NTS
Description:		Drawing Number: 4107 8574 56	
DWG INST HOSE REEL		DN: HOP200674	Rev: 00
Sheet 1 of 2		DO NOT SCALE THIS DOCUMENT	

GAS CONNECTION:
1/2" OD (0.049" WALL) TYPE K
COPPER INLET TUBE



Revised:	Date:	Drawn: SMB	Date: 12/17/2020
	This drawing and the information contained therein remain the property of BeaconMedaes and may not be used for other than the purpose for which it is loaned without the expressed written permission from BeaconMedaes Engineering.		Scale: NTS
Description:		Drawing Number:	4107 8574 56
DWG INST HOSE REEL		DN:	HOP200674
Sheet 2 of 2		Rev:	00
		DO NOT SCALE THIS DOCUMENT	